

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)  
CB SCHEME

## CB TEST CERTIFICATE

Product

Circuit-breakers for overcurrent protection for household and similar installations, Circuit-breakers for a.c. operation

Name and address of the applicant

Electromech Industries  
Plot no 6, sector iidc Sidcul  
Haridwar, Uttarakhand, 249403  
INDIA

Name and address of the manufacturer

Electromech Industries  
Plot no 6, sector iidc Sidcul  
Haridwar, Uttarakhand, 249403  
INDIA

Name and address of the factory

Note: When more than one factory, please report on page 2

Electromech Industries  
Plot no 6, sector iidc Sidcul Haridwar, Uttarakhand, 249403  
INDIA Additional Information on page 2

Ratings and principal characteristics

See Page 2

Trademark / Brand (if any)



Type of Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

AMBS1C10, AMBS1C16, AMBS1C20, AMBS1C25, AMBS1C32,  
AMBS1C40, AMBS1C6

Additional information (if necessary may also be reported on page 2)

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

4789111735A issued on 2020-03-20

This CB Test Certificate is issued by the National Certification Body

UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA  
UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK  
UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN  
UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADAFor full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2020-03-31

Signature:

Jan-Erik Storgaard

## Ratings:

No. of Poles : SP  
Rated Operational Voltage (Ue) : SP: 240 V  
Rated Operational Current (Ie) : 6A, 10A, 16A, 20A, 25A, 32A & 40A  
Rated Frequency : 50/60 Hz  
Rated service short circuit capacity (Ics) : 6 kA  
Rated short circuit capacity (Icn) : 6 kA  
Rated Impulse Withstand Voltage (Uimp) : 4 kV

## Additional Information:

Additionally evaluated to EN 60898-1:2003/A1:2004/A11:2006/A12:2008/A13:2012; National Differences specified in the CB Test Report.

**Additional information (if necessary)**

- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2020-03-31

Signature:



Jan-Erik Storgaard